



MINISTERIO
DE INDUSTRIA, ENERGÍA
Y TURISMO

MINISTRY OF INDUSTRY, ENERGY AND TOURISM
LICOFF: Official Laboratory for Fire Testing
R.D. 1614/1985 on 1st of August
M.O. on 21st of May of 1991



AFITI
LICOF Centre for Fire Testing
and Research

Association for the Promotion of Research and Fire Safety Technology

Test Certificate

Nº: C8650/12-8

English Version

Applicant

GAVE ELECTRO, S.L.
C/ Alfred Nobel nº 16
Pol. Ind. Valldoriolf
08430 - La Roca del Vallès (BARCELONA)

Building Element

Switch disconnecter
Manufacturer: Gave Electro, S.L.

Reference:

AB5524 F4	AL5524 F4
AB5522 F4	AL5522 F4
AB5564 F4	AL5564 F4
AB5562 F4	AL5562 F4
AB5566 F4	AL5566 F4
AB5526 F4	AL5526 F4

Test

Test protocol based on EN 12101-3:2002 "Smoke and heat control systems. Part 3: Specifications for powered smoke and heat exhaust ventilators"

Test Date

03rd-Feb-12

Certificate for the reports

Test report nr 8650/12-3 (issued by AFITI-LICOFF on 22nd-Oct-2012).

Fire Resistance Classification

F400 (I 20)

Classification taking as reference what is stated in §6.1.3. table 2 of the standard UNE-EN 12101-3:2002

Arganda del Rey, 22nd of October of 2012



Document Signed Digitally

Signed: Agustín Garzón Cabrerizo
Technical Director
Fire Resistance Laboratory
Technical Director of LICOFF

This Test Certificate nr C8650/12-8 supersedes the Test Certificate nr C8650/12-5 issued on 20th-mar-12

The results of this Certificate refer solely and exclusively to the specimens tested, and not to the product in general.

The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned Fire Resistance classification. This certificate should be used together with the referenced reports.

Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.

HEAD OFFICE & LABORATORIES Camino del Estrechillo, 8 E-28500 Arganda del Rey - Madrid (Spain)

CENTRAL OFFICE & LABORATORIES C/ Río Estenilla, s/n - P.I. Sta. M^a de Benquerencia E-45007 Toledo (Spain)

+34 902 112 942
+34 901 706 587
licof@afiti.com
www.afiti.com